

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**  
***Monitoring Requirements Not Met for City of Reading***

The City of Reading is required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did not complete monitoring for arsenic, monitor or test for total coliform bacteria, nor properly monitor or test for chlorine residuals during the monitoring period of April 1 through April 30, 2026. Therefore, we cannot be sure of the quality of your drinking water during that time.

**What should I do?** There is nothing you need to do at this time. This is not an emergency. You do not need to boil water or use an alternative source of water at this time. Even though this is not an emergency, as our customers, you have a right to know what happened and what we are doing to correct the situation.

The table below lists the contaminants we did not properly test for, how often we are supposed to sample for these contaminants, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date follow-up samples will be collected.

Contaminants	Required sampling frequency	Number of samples taken	Date samples should have been collected	Date follow up samples have been collected:
Arsenic	1 sample / month	0	April 1 – 30, 2026	May 7, 2026
Total Coliform Bacteria	2 sample / month	0	April 1 – 30, 2026	May 8, 2026
Chlorine Residual	2 samples / month	0	April 1 – 30, 2026	May 08, 2026

**What happened? What is being done?** We failed to collect an arsenic sample, bacteriological samples and chlorine residuals during April, 2026. Our staff is making every effort to assure this does not happen again. Follow up samples have been collected in May, 2026.

For more information, please contact City of Reading, Water Treatment Operator at 517.283.2604.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by the City of Reading.

Signature Paul D. Sygat Title: O.I.C. Date Distributed: 6/12/26

City of Reading - Iron/Arsenic Removal Plant and Chlorination & Iron Residuals											Mo/Yr: Apr-26								
MICHIGAN DEPARTMENT OF GREAT LAKES AND ENERGY																			
Day of Month	Treated Water Metered		Backwash Date	Iron (Mg/L)	SCADA Sheet	(SS) Math Conversion F/Accu-Tab Ca(OCl) <sub>2</sub>	Ca(OCl) lbs. Solution	Chlorination 12.5%			Plant Tap Chlorine		Dist. Chlorine #1		Dist. Chlorine #2		Dist. Chlorine #3		
	Million Gallons	Million Pounds						Ca(OCl) <sub>2</sub> Applied (lbs. 12.5%)	Ca(OCl) <sub>2</sub> Applied (lbs. pure)	Ca(OCl) <sub>2</sub> Applied Mg/L	Free Chlorine Mg/L	Total Chlorine Mg/L	Free Chlorine Mg/L	Total Chlorine Mg/L	Free Chlorine Mg/L	Total Chlorine Mg/L	Free Chlorine Mg/L	Total Chlorine Mg/L	
	1	0.0928						0.774	X	0.027	1.44	14.39	29.51	29.5	3.69	4.76	0.67	1.04	
2	0.0865	0.721			1.34	13.41	27.49	27.5	3.44	4.76									
3	0.0625	0.521		0.021	0.97	9.69	19.87	19.9	2.49	4.77	0.98	1.03	0.25	0.42	0.23	0.45	0.21	0.29	
4	0.0603	0.503			0.93	9.35	19.16	19.2	2.40	4.77									
5	0.0876	0.731			1.36	13.58	27.84	27.9	3.49	4.77									
6	0.1218	1.016		0.021	1.89	18.88	38.71	38.8	4.85	4.77	0.95	1.20							
7	0.1254	1.046			1.94	19.44	39.85	39.9	4.99	4.77									
8	0.1247	1.040	X	0.018	1.93	19.33	39.63	39.7	4.96	4.77	0.78	1.10							
9	0.1163	0.970			1.80	18.03	36.97	37.0	4.63	4.77									
10	0.0970	0.809		0.012	1.50	15.04	30.82	30.9	3.86	4.78	0.30	0.50							
11	0.0597	0.497			0.92	9.25	18.96	19.0	2.38	4.77									
12	0.0915	0.763			1.42	14.19	29.09	29.1	3.64	4.77									
13	0.1309	1.092		0.014	2.03	20.29	41.60	41.6	5.20	4.76	0.22	0.47							
14	0.0908	0.758			1.41	14.08	28.87	28.9	3.61	4.77									
15	0.0971	0.810	X	0.008	1.51	15.05	30.85	30.9	3.86	4.77	0.74	12.39							
16	0.0891	0.743			1.38	13.81	28.32	28.4	3.55	4.78									
17	0.0583	0.486		0.023	0.90	9.04	18.53	18.6	2.33	4.78	0.58	0.84	0.13	0.20	0.10	0.18	0.08	0.16	
18	0.0846	0.705			1.31	13.11	26.88	26.9	3.36	4.77									
19	0.0680	0.567			1.05	10.54	21.61	21.7	2.71	4.78									
20	0.0887	0.739		0.022	1.37	13.74	28.18	28.2	3.53	4.77	0.77	1.04							
21	0.0609	0.508			0.94	9.44	19.35	19.4	2.43	4.78									
22	0.1308	1.091	X	0.021	2.03	20.28	41.57	41.6	5.20	4.77	0.92	1.20							
23	0.0577	0.481			0.89	8.94	18.33	18.4	2.30	4.78									
24	0.0878	0.732		0.022	1.36	13.62	27.91	28.0	3.50	4.78	0.94	1.23	0.05	0.16	0.11	0.21	0.05	0.13	
25	0.0617	0.515			0.96	9.57	19.62	19.7	2.46	4.78									
26	0.0696	0.580			1.08	10.79	22.11	22.2	2.78	4.78									
27	0.0922	0.769		0.033	1.43	14.30	29.32	29.4	3.68	4.78	0.93	1.17							
28	0.0575	0.479			0.89	8.91	18.27	18.3	2.29	4.77									
29	0.1229	1.025	X	0.036	1.91	19.06	39.07	39.1	4.89	4.77	0.77	1.11							
30	0.0666	0.556			1.03	10.33	21.17	21.2	2.65	4.77									
Total	2.641	22.028					839.48	840.91	105.11										
Ave.	0.088	0.734		0.021	1.37	13.7	27.98	28.03	3.50	4.77	0.73	1.87	0.14	0.26	0.15	0.28	0.11	0.19	
Max.	0.131	1.092		0.036	2.03	20.3	41.60	41.60	5.20	4.78	0.98	12.39	0.25	0.42	0.23	0.45	0.21	0.29	
Min.	0.057	0.479		0.008	0.89	8.9	18.27	18.30	2.29	4.76	0.22	0.47	0.05	0.16	0.10	0.18	0.05	0.13	